

**TENT CHECKLIST MUST BE COMPLETED, SIGNED AND SUBMITTED WITH APPLICATION**

Chapter 31 (NYS Fire Code) Tents and Other Membrane Structures

Section 3101 General

3101.1 Scope

Tents, temporary stage canopies and membrane structures shall comply with this chapter. The provisions of Section 3103 are applicable only to temporary tents and membrane structures. The provisions of Section 3104 are applicable to temporary and permanent tents and membrane structures. Other temporary structures shall comply with the International Building Code.

Section 3103 Temporary Tents and Membrane Structures

3103.1 General

Tents and membrane structures used for temporary periods shall comply with this section. Other temporary structures erected for a period of 180 days or less shall comply with the International Building Code.

3103.2 Approval Required

Tents and membrane structures having an area in excess of 400 square feet (37 m<sup>2</sup>) shall not be erected, operated or maintained for any purpose without first obtaining a permit and approval from the fire code official.

Exceptions:

1. Tents used exclusively for recreational camping purposes.
2. Tents open on all sides that comply with all of the following:
  - 2.1. Individual tents having a maximum size of 700 square feet (65 m<sup>2</sup>).
  - 2.2. The aggregate area of multiple tents placed side by side without a fire break clearance of 12 feet (3658 mm), not exceeding 700 square feet (65 m<sup>2</sup>) total.
  - 2.3. A minimum clearance of 12 feet (3658 mm) to all structures and other tents.

3103.3 Place of Assembly

For the purposes of this chapter, a place of assembly shall include a circus, carnival, tent show, theater, skating rink, dance hall or other place of assembly in or under which persons gather for any purpose.

Not applicable; or  Explained in attached narrative

### 3103.4 Permits

### 3103.5 Use Period

Temporary tents, air-supported, air-inflated or tensioned membrane structures shall not be erected for a period of more than 180 days within a 12-month period on a single premises.

Time period of your event: \_\_\_\_\_

### 3103.6 Construction Documents

A detailed site and floor plan for tents or membrane structures with an occupant load of 50 or more shall be provided with each application for approval. The tent or membrane structure floor plan shall indicate details of the means of egress facilities, seating capacity, arrangement of the seating and location and type of heating and electrical equipment.

Site Plan Included

Floor plan included

### 3103.7 Inspections

The entire tent, air-supported, air-inflated or tensioned membrane structure system shall be inspected at regular intervals, but not less than two times per permit use period, by the permittee, owner or agent to determine that the installation is maintained in accordance with this chapter.

Exception: Permit use periods of less than 30 days.

Not applicable. Event is less than 30 days

#### 3103.7.1 Inspection Report

Where required by the fire code official, an inspection report shall be provided and shall consist of maintenance, anchors and fabric inspections.

Not required for a one day event

### 3103.8 Access, Location and Parking

Access, location and parking for temporary tents and membrane structures shall be in accordance with this section.

#### 3103.8.1 Access

Fire apparatus access roads shall be provided in accordance with Section 503.

Main access road depicted on site plan

#### 3103.8.2 Location

Tents or membrane structures shall not be located within 20 feet (6096 mm) of lot lines, buildings, other tents or membrane structures, parked vehicles or internal combustion engines. For the purpose of determining required distances, support ropes and guy wires shall be considered as part of the temporary membrane structure or tent.

Depict distances on site plan; or

Exception(s) apply. Please circle below.

Exceptions:

1. Separation distance between membrane structures and tents not used for cooking is not required where the aggregate floor area does not exceed 15,000 square feet (1394 m<sup>2</sup>).

2. Membrane structures or tents need not be separated from buildings when all of the following conditions are met:

2.1. The aggregate floor area of the membrane structure or tent shall not exceed 10,000 square feet (929 m<sup>2</sup>).

2.2. The aggregate floor area of the building and membrane structure or tent shall not exceed the allowable floor area including increases as indicated in the International Building Code.

2.3. Required means of egress are provided for both the building and the membrane structure or tent including travel distances.

2.4. Fire apparatus access roads are provided in accordance with Section 503.

### 3103.8.3 Location of Structures in Excess of 15,000 Square Feet in Area

Membrane structures having an area of 15,000 square feet (1394 m<sup>2</sup>) or more shall be located not less than 50 feet (15 240 mm) from any other tent or structure as measured from the sidewall of the tent or membrane structure unless joined together by a corridor.

Not applicable; or  depicted on site plan

### 3103.8.4 Membrane Structures on Buildings

Membrane structures that are erected on buildings, balconies, decks or other structures shall be regulated as permanent membrane structures in accordance with Section 3102 of the International Building Code.

Not applicable

#### 3103.8.5 Connecting Corridors

Tents or membrane structures are allowed to be joined together by means of corridors. Exit doors shall be provided at each end of such corridor. On each side of such corridor and approximately opposite each other, there shall be provided openings not less than 12 feet (3658 mm) wide.

Not applicable; or  depicted on floor plan

#### 3103.8.6 Fire Break

An unobstructed fire break passageway or fire road not less than 12 feet (3658 mm) wide and free from guy ropes or other obstructions shall be maintained on all sides of all tents and membrane structures unless otherwise approved by the fire code official.

Depicted on site plan

#### 3103.9 Anchorage Required

Tents or membrane structures and their appurtenances shall be adequately roped, braced and anchored to withstand the elements of weather and prevent against collapsing. Documentation of structural stability shall be furnished to the fire code official on request.

Submitted with application.

#### 3103.9.1 Tents and Membrane Structures Exceeding One Story

Tents and membrane structures exceeding one story shall be designed and constructed to comply with Chapter 16 of the International Building Code.

Not applicable

#### 3103.10 Temporary Air-Supported and Air-Inflated Membrane Structures

Temporary air-supported and air-inflated membrane structures shall be in accordance with Sections 3103.10.1 through 3103.10.4.

Not applicable; or  Depicted on site plan

#### 3103.10.1 Door Operation

During high winds exceeding 50 miles per hour (22 m/s) or in snow conditions, the use of doors in air-supported structures shall be controlled to avoid excessive air loss. Doors shall not be left open.

Not Applicable; or  included compliance as part of the narrative

#### 3103.10.2 Fabric Envelope Design and Construction

Air-supported and air-inflated structures shall have the design and construction of the fabric envelope and the method of anchoring in accordance with Architectural Fabric Structures Institute ASI 77.

Not Applicable; or  included compliance as part of the narrative

### 3103.10.3 Blowers

An air-supported structure used as a place of assembly shall be furnished with not less than two blowers, each of which has adequate capacity to maintain full inflation pressure with normal leakage. The design of the blower shall be so as to provide integral limiting pressure at the design pressure specified by the manufacturer.

Not applicable; or  included in construction documents

### 3103.10.4 Auxiliary Inflation Systems

Places of public assembly for more than 200 persons shall be furnished with an auxiliary inflation system capable of powering a blower with the capacity to maintain full inflation pressure with normal leakage in accordance with Section 3103.10.3 for a minimum duration of 4 hours. The auxiliary inflation system shall be either a fully automatic auxiliary engine-generator set or a supplementary blower powered by an internal combustion engine that shall be automatic in operation. The system shall be capable of automatically operating the required blowers at full power within 60 seconds of a commercial power failure.

Not applicable; or  Included in construction documents

### 3103.11 Seating Arrangements

Seating in tents or membrane structures shall be in accordance with Chapter 10.

Depicted on floor plan.

### 3103.12 Means of Egress

Means of egress for temporary tents and membrane structures shall be in accordance with Sections 3103.12.1 through 3103.12.8.

Depicted on floor plan

#### 3103.12.1 Distribution

Exits shall be spaced at approximately equal intervals around the perimeter of the tent or membrane structure, and shall be located such that all points are 100 feet (30 480 mm) or less from an exit.

Depicted on floor plan

#### 3103.12.2 Number

Tents, or membrane structures or a usable portion thereof shall have not less than one exit and not less than the number of exits required by Table 3103.12.2. The total width of means of egress in inches (mm) shall be not less than the total occupant load served by a means of egress multiplied by 0.2 inches (5 mm) per person.

Depicted on floor plan

TABLE 3103.12.2 MINIMUM NUMBER OF MEANS OF EGRESS AND MEANS OF EGRESS WIDTHS FROM TEMPORARY MEMBRANE STRUCTURES AND TENTS

OCCUPANT LOAD            MINIMUM NUMBER OF MEANS  
OF EGRESS                MINIMUM WIDTH OF EACH MEANS OF  
EGRESS (inches)        MINIMUM WIDTH OF EACH MEANS OF  
EGRESS (inches)

Tent	Membrane Structure		
10 to 199	2	72	36
200 to 499	3	72	72
500 to 999	4	96	72
1,000 to 1,999	5	120	96
2,000 to 2,999	6	120	96
Over 3,000a	7	120	96

Included on Floor plan

For SI: 1 inch = 25.4 mm.

a. When the occupant load exceeds 3,000, the total width of means of egress (in inches) shall be not less than the total occupant load multiplied by 0.2 inches per person.

Not Applicable

### 3103.12.3 Exit Openings From Tents

Exit openings from tents shall remain open unless covered by a flame-resistant curtain. The curtain shall comply with the following requirements:

1. Curtains shall be free sliding on a metal support. The support shall be not less than 80 inches (2032 mm) above the floor level at the exit. The curtains shall be so arranged that, when open, no part of the curtain obstructs the exit.

Depicted on floor plan; or  Not applicable

2. Curtains shall be of a color, or colors, that contrasts with the color of the tent.

#### 3103.12.4 Doors

Exit doors shall swing in the direction of exit travel. To avoid hazardous air and pressure loss in air-supported membrane structures, such doors shall be automatic closing against operating pressures. Opening force at the door edge shall not exceed 15 pounds (66 N).

Depicted on floor plan; or  Not applicable

#### 3103.12.5 Aisle

The width of aisles without fixed seating shall be in accordance with the following:

1. In areas serving employees only, the minimum aisle width shall be 24 inches (610 mm) but not less than the width required by the number of employees served.

Depicted on floor plan; or  Not applicable

2. In public areas, smooth-surfaced, unobstructed aisles having a minimum width of not less than 44 inches (1118 mm) shall be provided from seating areas, and aisles shall be progressively increased in width to provide, at all points, not less than 1 foot (305 mm) of aisle width for each 50 persons served by such aisle at that point.

Depicted on floor plan; or  Not applicable

##### 3103.12.5.1 Arrangement and Maintenance

The arrangement of aisles shall be subject to approval by the fire code official and shall be maintained clear at all times during occupancy.

**Site plan and floor plan will be approved prior to the issuance of a permit**

#### 3103.12.6 Exit Signs

Exits shall be clearly marked. Exit signs shall be installed at required exit doorways and where otherwise necessary to indicate clearly the direction of egress where the exit serves an occupant load of 50 or more.

Depicted on Floor Plan; or  Not applicable as the occupant load is less than 50

##### 3103.12.6.1 Exit Sign Illumination

Exit signs shall be either listed and labeled in accordance with UL 924 as the internally illuminated type and used in accordance with the listing or shall be externally illuminated by luminaires supplied in either of the following manners:

1. Two separate circuits, one of which shall be separate from all other circuits, for occupant loads of 300 or less.

2. Two separate sources of power, one of which shall be an approved emergency system, shall be provided where the occupant load exceeds 300. Emergency systems shall be supplied from storage batteries or from the on-site generator set, and the system shall be installed in accordance with NFPA 70. The emergency system provided shall have a minimum duration of 90 minutes when operated at full design demand.

#### 3103.12.7 Means of Egress Illumination

Means of egress shall be illuminated with light having an intensity of not less than 1 footcandle (11 lux) at floor level while the structure is occupied. Fixtures required for means of egress illumination shall be supplied from a separate circuit or source of power.

Depicted on floor plan

#### 3103.12.8 Maintenance of Means of Egress

The required width of exits, aisles and passageways shall be maintained at all times to a public way. Guy wires, guy ropes and other support members shall not cross a means of egress at a height of less than 8 feet (2438 mm). The surface of means of egress shall be maintained in an approved manner.

### Section 3104 Temporary and Permanent Tents and Membrane Structures

#### 3104.1 General

Tents and membrane structures, both temporary and permanent, shall be in accordance with this section. Permanent tents and membrane structures shall also comply with the International Building Code.

#### 3104.2 Flame Propagation Performance Treatment

Before a permit is granted, the owner or agent shall file with the fire code official a certificate executed by an approved testing laboratory certifying that the tents and membrane structures and their appurtenances; sidewalls, drops and tarpaulins; floor coverings, bunting and combustible decorative

materials and effects, including sawdust where used on floors or passageways, are composed of material meeting the flame propagation performance criteria of Test Method 1 or Test Method 2, as appropriate, of NFPA 701 or shall be treated with a flame retardant in an approved manner and meet the flame propagation performance criteria of Test Method 1 or Test Method 2, as appropriate, of NFPA 701, and that such flame propagation performance criteria are effective for the period specified by the permit.

Certificate executed by an approved testing laboratory included

#### 3104.3 Label



Membrane structures or tents shall have a permanently affixed label bearing the identification of size and fabric or material type.

This will be inspected for compliance

#### 3104.4 Certification

An affidavit or affirmation shall be submitted to the fire code official and a copy retained on the premises on which the tent or air-supported structure is located. The affidavit shall attest to all of the following information relative to the flame propagation performance criteria of the fabric:

1. Names and address of the owners of the tent or air-supported structure.
2. Date the fabric was last treated with flame-retardant solution.
3. Trade name or kind of chemical used in treatment.
4. Name of person or firm treating the material.
5. Name of testing agency and test standard by which the fabric was tested.

This affidavit or affirmation has been included with the construction documents

#### 3104.5 Combustible Materials

Hay, straw, shavings or similar combustible materials shall not be located within any tent or membrane structure containing an assembly occupancy, except the materials necessary for the daily feeding and care of animals. Sawdust and shavings utilized for a public performance or exhibit shall not be prohibited provided the sawdust and shavings are kept damp. Combustible materials shall not be permitted under stands or seats at any time.

Check here to acknowledge that you read and understand the above instructions

#### 3104.6 Smoking

Smoking shall not be permitted in tents or membrane structures. Approved "No Smoking" signs shall be conspicuously posted in accordance with Section 310.

Depicted on floor plan

#### 3104.7 Open or Exposed Flame

Open flame or other devices emitting flame, fire or heat or any flammable or combustible liquids, gas, charcoal or other cooking device or any other unapproved devices shall not be permitted inside or located within 20 feet (6096 mm) of the tent or membrane structures while open to the public unless approved by the fire code official.

If this is applicable it needs to be shown on the plans and approved as part of the plan review prior to a permit being issued.

#### 3104.8 Fireworks

Fireworks shall not be used within 100 feet (30 480 mm) of tents or membrane structures.

Check here to acknowledge that read and understand the above instruction.

#### 3104.9 Spot Lighting

Spot or effect lighting shall only be by electricity, and all combustible construction located within 6 feet (1829 mm) of such equipment shall be protected with approved noncombustible insulation not less than 91/4 inches (235 mm) thick.

Not applicable; or  Spot lighting location is depicted on plans

#### 3104.10 Safety Film

Motion pictures shall not be displayed in tents or membrane structures unless the motion picture film is safety film.

Check here to acknowledge that you read and understand the above instruction.

#### 3104.11 Clearance

There shall be a minimum clearance of at least 3 feet (914 mm) between the fabric envelope and all contents located inside membrane structures.

Depicted on plan

#### 3104.12 Portable Fire Extinguishers

Portable fire extinguishers shall be provided as required by Section 906.

Location of portable fire extinguisher depicted on floor plan

#### 3104.13 Fire Protection Equipment

Fire hose lines, water supplies and other auxiliary fire equipment shall be maintained at the site in such numbers and sizes as required by the fire code official.

Not applicable

#### 3104.14 Occupant Load Factors

The occupant load allowed in an assembly structure, or portion thereof, shall be determined in accordance with Chapter 10.

Occupant load in accordance with Chapter 10 to be clearly indicated by Tent company on the floor plan

#### 3104.15 Heating and Cooking Equipment

Heating and cooking equipment shall be in accordance with Sections 3104.15.1 through 3104.15.7.

### 3104.15.1 Installation

Heating or cooking equipment, tanks, piping, hoses, fittings, valves, tubing and other related components shall be installed as specified in the International Mechanical Code and the International Fuel Gas Code, and shall be approved by the fire code official.

### 3104.15.2 Venting

Gas, liquid and solid fuel-burning equipment designed to be vented shall be vented to the outside air as specified in the International Fuel Gas Code and the International Mechanical Code. Such vents shall be equipped with approved spark arresters where required. Where vents or flues are used, all portions of the tent or membrane structure shall be not less than 12 inches (305 mm) from the flue or vent.

Not applicable; or  depicted on plans indicating all compliance methods

### 3104.15.3 Location

Cooking and heating equipment shall not be located within 10 feet (3048 mm) of exits or combustible materials.

Not applicable; or  depicted on floor plan

### 3104.15.4 Operations

Operations such as warming of foods, cooking demonstrations and similar operations that use solid flammables, butane or other similar devices that do not pose an ignition hazard, shall be approved.

Depicted on floor plan; or  not applicable

### 3104.15.5 Cooking Tents

Tents with sidewalls or drops where cooking is performed shall be separated from other tents or membrane structures by not less than 20 feet (6096 mm).

Not applicable; or  depicted on floor plan

### 3104.15.6 Outdoor Cooking

Outdoor cooking that produces sparks or grease-laden vapors shall not be performed within 20 feet (6096 mm) of a tent or membrane structure.

Check here to acknowledge that you have read and understand; or

Not Applicable

### 3104.15.7 Electrical Heating and Cooking Equipment

Electrical cooking and heating equipment shall comply with NFPA 70.

Check here to acknowledge that you have read and understand; or

Not applicable

### 3104.16 LP-gas

The storage, handling and use of LP-gas and LP-gas equipment shall be in accordance with Sections 3104.16.1 through 3104.16.3.

Check here to acknowledge that you have read and understand; or

Not applicable

#### 3104.16.1 General

LP-gas equipment such as tanks, piping, hoses, fittings, valves, tubing and other related components shall be approved and in accordance with Chapter 61 and with the International Fuel Gas Code.

Check here to acknowledge that you have read and understand; or

Not applicable

#### 3104.16.2 Location of Containers

LP-gas containers shall be located outside. Safety release valves shall be pointed away from the tent or membrane structure.

Check here to acknowledge that you have read and understand; or

Not Applicable

##### 3104.16.2.1 Containers 500 Gallons or Less

Portable LP-gas containers with a capacity of 500 gallons (1893 L) or less shall have a minimum separation between the container and structure not less than 10 feet (3048 mm).

Not applicable; or  Depicted on plans

##### 3104.16.2.2 Containers More Than 500 Gallons

Portable LP-gas containers with a capacity of more than 500 gallons (1893 L) shall have a minimum separation between the container and structures not less than 25 feet (7620 mm).

Not applicable; or  Depicted on plans

#### 3104.16.3 Protection and Security

Portable LP-gas containers, piping, valves and fittings that are located outside and are being used to fuel equipment inside a tent or membrane structure shall be adequately protected to prevent tampering, damage by vehicles or other hazards and shall be located in an approved location. Portable LP-gas containers shall be securely fastened in place to prevent unauthorized movement.

Not applicable; or  Depicted on plans

#### 3104.17 Flammable and Combustible Liquids

The storage of flammable and combustible liquids and the use of flammable-liquid-fueled equipment shall be in accordance with Sections 3104.17.1 through 3104.17.3.

Check here to acknowledge that you have read and understand; or

Not applicable

##### 3104.17.1 Use

Flammable-liquid-fueled equipment shall not be used in tents or membrane structures.

Check here to acknowledge that you have read and understand

##### 3104.17.2 Flammable and Combustible Liquid Storage

Flammable and combustible liquids shall be stored outside in an approved manner not less than 50 feet (15 240 mm) from tents or membrane structures. Storage shall be in accordance with Chapter 57.

Not applicable; or  depicted on plans

##### 3104.17.3 Refueling

Refueling shall be performed in an approved location not less than 20 feet (6096 mm) from tents or membrane structures.

Not applicable; or

Check here to acknowledge that you have read and understand

#### 3104.18 Display of Motor Vehicles

Liquid- and gas-fueled vehicles and equipment used for display within tents or membrane structures shall be in accordance with Sections 3104.18.1 through 3104.18.5.3.

Not applicable; or

Check here to acknowledge that you have read and understand

##### 3104.18.1 Batteries

Batteries shall be disconnected in an appropriate manner.

Not applicable; or

Check here to acknowledge that you have read and understand

#### 3104.18.2 Fuel

Vehicles or equipment shall not be fueled or defueled within the tent or membrane structure.

Not applicable; or

Check here to acknowledge that you have read and understand

##### 3104.18.2.1 Quantity Limit

Fuel in the fuel tank shall not exceed one-quarter of the tank capacity or 5 gallons (19 L), whichever is less.

Not applicable; or

Check here to acknowledge that you have read and understand

##### 3104.18.2.2 Inspection

Fuel systems shall be inspected for leaks.

Not applicable; or

Check here to acknowledge that you have read and understand

##### 3104.18.2.3 Closure

Fuel tank openings shall be locked and sealed to prevent the escape of vapors.

Not applicable; or

Check here to acknowledge that you have read and understand

#### 3104.18.3 Location

The location of vehicles or equipment shall not obstruct means of egress.

Not applicable; or

Check here to acknowledge that you have read and understand

#### 3104.18.4 Places of Assembly

When a compressed natural gas (CNG) or liquefied petroleum gas (LP-gas) powered vehicle is parked inside a place of assembly, all the following conditions shall be met:

1. The quarter-turn shutoff valve or other shutoff valve on the outlet of the CNG or LP-gas container shall be closed and the engine shall be operated until it stops. Valves shall remain closed while the vehicle is indoors.

Not applicable; or

Check here to acknowledge that you have read and understand

2. The hot lead of the battery shall be disconnected.

Not applicable; or

Check here to acknowledge that you have read and understand

3. Dual-fuel vehicles equipped to operate on gasoline and CNG or LP-gas shall comply with this section and Sections 3104.18.1 through 3104.18.5.3 for gasoline-powered vehicles.

Not applicable; or

Check here to acknowledge that you have read and understand

#### 3104.18.5 Competitions and Demonstrations

Liquid and gas-fueled vehicles and equipment used for competition or demonstration within a tent or membrane structure shall comply with Sections 3104.18.5.1 through 3104.18.5.3.

Not applicable; or

Check here to acknowledge that you have read and understand

#### 3104.18.5.1 Fuel Storage

Fuel for vehicles or equipment shall be stored in approved containers in an approved location outside of the structure in accordance with Section 3104.17.2.

Not applicable; or

Check here to acknowledge that you have read and understand

#### 3104.18.5.2 Fueling

Refueling shall be performed outside of the structure in accordance with Section 3104.17.3.

Not applicable; or

Check here to acknowledge that you have read and understand

#### 3104.18.5.3 Spills

Fuel spills shall be cleaned up immediately.

Not applicable; or

Check here to acknowledge that you have read and understand

#### 3104.19 Separation of Generators

Generators and other internal combustion power sources shall be separated from tents or membrane structures by not less than 20 feet (6096 mm) and shall be isolated from contact with the public by fencing, enclosure or other approved means.

Not applicable; or  Depicted on plans

3104.20 Standby Personnel; How many people will be in attendance you're your event \_\_\_\_\_

Where, in the opinion of the fire code official, it is essential for public safety in a tent or membrane structure used as a place of assembly or any other use where people congregate, because of the number of persons, or the nature of the performance, exhibition, display, contest or activity, the owner, agent or lessee shall employ one or more qualified persons, as required and approved, to remain on duty during the times such places are open to the public, or when such activity is being conducted.

Check here to acknowledge that you have read and understand

##### 3104.20.1 Duties

Before each performance or the start of such activity, standby personnel shall keep diligent watch for fires during the time such place is open to the public or such activity is being conducted and take prompt measures for extinguishment of fires that occur and assist in the evacuation of the public from the structure.

Check here to acknowledge that you have read and understand

##### 3104.20.2 Crowd Managers

There shall be trained crowd managers or crowd manager/supervisors at a ratio of one crowd manager/supervisor for every 250 occupants, as approved.

Check here to acknowledge that you have read and understand

##### 3104.21 Combustible Vegetation

Combustible vegetation that could create a fire hazard shall be removed from the area occupied by a tent or membrane structure, and from areas within 30 feet (9144 mm) of such structures.

Check here to acknowledge that you have read and understand and depicted on site plan



### 3104.22 Combustible Waste Material

The floor surface inside tents or membrane structures and the grounds outside and within a 30-foot (9144 mm) perimeter shall be kept free of combustible waste and other combustible materials that could create a fire hazard. Such waste shall be stored in approved containers and removed from the premises not less than once a day during the period the structure is occupied by the public.

Check here to acknowledge that you have read and understand and depicted on site plan

## Section 3105 Temporary Stage Canopies

### 3105.1 General

Temporary stage canopies shall comply with Section 3104, Sections 3105.2 through 3105.8 and ANSI E1.21.

Not applicable – Your checklist is now complete. Thank you.

### 3105.2 Approval

Temporary stage canopies in excess of 400 square feet (37 m<sup>2</sup>) shall not be erected, operated or maintained for any purpose without first obtaining approval and a permit from the fire code official and the building official.

## Section 3105 Temporary Stage Canopies (con't)

### 3105.3 Permits

Permits shall be required as set forth in Sections 105.6 and 105.7.

UpCodes note: Section 7.2 of the New York State 2017 Uniform Code Supplement indicates references to the original IFC section 105.6 and 105.7 to be replaced by the following requirements:

Any provision in the 2015 IFC that indicates that a permit is required shall be deemed to be amended to indicate that a permit is required to the extent provided in:

the stricter of (i) the Code Enforcement Program of the Authority Having Jurisdiction or (ii) a Part 1203-Compliant Code Enforcement Program,

Section 109 of the amended and restated version of Chapter 1 found in this Supplement, and/or

19 NYCRR Part 1228 (“Sugarhouse Alternative Activity Provisions”).

3105.4 Use Period; Temporary stage canopies shall not be erected for a period of more than 45 days.

#### 3105.5 Required Documents

The following documents shall be submitted to the fire code official and the building official for review before a permit is approved:

1. Construction documents: Construction documents shall be prepared in accordance with the International Building Code by a registered design professional. Construction documents shall include:

1.1. A summary sheet showing the building code used, design criteria, loads and support reactions.

1.2. Detailed construction and installation drawings.

1.3. Design calculations.

1.4. Operating limits of the structure explicitly outlined by the registered design professional including environmental conditions and physical forces.

1.5. Effects of additive elements such as video walls, supported scenery, audio equipment, vertical and horizontal coverings.

1.6. Means for adequate stability including specific requirements for guying and cross-bracing, ground anchors or ballast for different ground conditions.

2. Designation of responsible party: The owner of the temporary stage canopy shall designate in writing a person to have responsibility for the temporary stage canopy on the site. The designated person shall have sufficient knowledge of the construction documents, manufacturer's recommendations and operations plan to make judgments regarding the structure's safety and to coordinate with the fire code official.

3. Operations plan: The operations plan shall reflect manufacturer's operational guidelines, procedures for environmental monitoring and actions to be taken under specified conditions consistent with the construction documents.

#### 3105.6 Inspections

Inspections shall comply with Section 106 and Sections 3105.6.1 and 3105.6.2.

##### 3105.6.1 Independent Inspector

The owner of a temporary stage canopy shall employ a qualified, independent approved agency or individual to inspect the installation of a temporary stage canopy.

#### 3105.6.2 Inspection Report

The inspecting agency or individual shall furnish an inspection report to the fire code official. The inspection report shall indicate that the temporary stage canopy was inspected and was or was not installed in accordance with the approved construction documents. Discrepancies shall be brought to the immediate attention of the installer for correction. Where any discrepancy is not corrected, it shall be brought to the attention of the fire code official and the designated responsible party.

#### 3105.7 Means of Egress

The means of egress for temporary stage canopies shall comply with Chapter 10.

#### 3105.8 Location

Temporary stage canopies shall be located a distance from property lines and buildings to accommodate distances indicated in the construction drawings for guy wires, cross-bracing, ground anchors or ballast. Location shall not interfere with egress from a building or encroach on fire apparatus access roads.